

Chesterfield Fire and EMS

Fire and Life Safety Division

HORIZONTAL STANDPIPES

(804) 748-1426

Fax: (804) 768-8766

www.chesterfield.gov/publicsafety/fire/plans.asp

HORIZONTAL STANDPIPE SYSTEM

NFPA - 24

Project Name : _____

Project Address : _____

Building Permit #: _____ Date : _____

Code Edition: _____

All supporting documentation showing items listed below are required for review.

General (All submissions shall include the following):

- ☐ Plans and calculations shall be provided as needed, per applicable National Standards and Codes.
- ☐ Plans shall clearly indicate the name of owner and/or occupant, project street address, tenant space designation, the responsible designer's name, address, and telephone number.
- ☐ Drawings are to be uniform size and drawn to a recognize scale.
- ☐ Provide a method of maintaining the ball drip/drain vault free of all standing water. The method of maintaining the vault free of standing water shall be one of the following:
 - ☐ Sump and drain line to storm sewer or acceptable daylight location.
 - ☐ Sump pump and drain line to storm sewer or acceptable daylight location.
- ☐ Show the point of connection and location of the Fire Department Connection (FDC) and Fire Department hose connection.
- ☐ Plans shall show the location of nearest fire hydrant (within 50' of FDC).
- ☐ Submitted plans shall indicate the minimum depth of cover for all Fire Protection Underground Piping. The minimum depth of cover shall be 3'-6" in accordance with the recommended depth of cover shown in NFPA 24 – 8-1.1.

- ☐ Submitted plans shall indicate the location of **ALL** thrust blocks, rodding and restraint devices being used. Thrust blocks shall be installed in accordance with NFPA-24 and the tables listed in this review checklist.
- ☐ Plans shall clearly indicate the method of providing corrosion protection after installation of rods, nuts, bolts, washers, clamps and other restraining devices, except thrust blocks, in accordance with the latest referenced edition of NFPA 24.
- ☐ Plans shall include thrust block bearing area table(s), thrust block details, water pressure, soil resistance pressure and minimum thrust block concrete requirements in accordance with NFPA 24, see attached thrust block bearing area and details.
- ☐ Provide the following manufacturer's product data sheets with the submitted plans required above:
 - ☐ Ball drip valve
 - ☐ Sump pump if required and shown in the above referenced plan submittal.
 - ☐ Access door to vault
 - ☐ Pipe penetration seals at vault (flexible)
 - ☐ Pre-fabricated vault construction details in referenced in above plan submittal.
 - ☐ Fire department connection with 2½" NST hose connections (Female/Male).
 - ☐ Pipe, fittings and restraint devices, including fire department connection (FDC), piping and fittings.
 - ☐ Other

Table 8-6.2.8 Area of Bearing Face Required for Concrete Thrust Blocks

Pipe Size	90° Bend		45° Bend		Tees, Plugs, Caps, And Hydrants	
in.	ft ²	m ²	ft ²	m ²	ft ²	m ²
4	2	0.19	2	0.19	2	0.19
6	5	0.46	3	0.28	4	0.37
8	8	0.74	5	0.46	6	0.56
10	13	1.21	7	0.65	9	0.84
12	18	1.67	10	0.93	13	1.21
14	25	2.32	14	1.30	18	1.67
16	32	2.97	18	1.67	23	2.14

Areas in table have been derived using a water pressure of 225 pounds per square inch (15.5 bars) and a soil resistance of 2000 pounds per square foot (1.0 bars). The values given in this table include a design safety factor of 1.5.

Minimum Amount of Concrete Required for Thrust Blocking	
Size of Fitting	Cubic Yards
3"-8"	$\frac{3}{4}$
10"-12"	1 $\frac{1}{2}$
16"-24"	2

ROD NUMBER – DIAMETER COMBINATIONS NUMBER OF RODS				
Nominal Pipe Size inches	5/8 in. (15.9 mm)	3/4 in. (19.1 mm)	7/8 in. (22.2 mm)	1 in. (25.4 mm)
4	2	————	————	————
6	2	————	————	————
8	3	2	————	————
10	4	3	2	————
12	6	4	3	2
14	8	5	4	3
16	10	7	5	4

Table has been derived using pressure of 225 psi (15.5 bars) and design stress of 25,000 psi (172.4 MPA.)